



Enquiries: LC Spies

Tel No: 044-8019111

Our ref: Portion 130, 131 and 132 of Gwayang 208

2 November 2021

Clinkscales Maughan-Brown (South) (Pty) Ltd
P.O. Box 2551
GEORGE
6530

Attention: Mr. R. Steenekamp

By E-Mail: rsteenekamp@cmbgeorge.co.za

Dear Sir

PROPOSED DEVELOPMENT ON PORTION 130, 131 and 132 OF THE FARM GWAYANG NO. 208, GEORGE

Your Electrical Services Report G/11832/R dated 1 October 2021 has reference.

We hereby take note of the contents of the services report. The technical details of the installation will be finalised once an approved Site Development Plan is available and the Services Agreement is compiled.

The additional capacity required for this Development (954kVA) will have to be transferred to the site by strengthening the existing network, as indicated in the report. The Development will be required to make a contribution towards or implement this Link Services on a pro-rata basis based on the demand of the Development. After completion of the Link Services, the additional capacity (954kVA) will be available for the development.

We trust that the above information is sufficient for the statutory approval process to be concluded.

Yours faithfully

Chris Spies

**Deputy Director Planning and Design (Contractual)
Directorate Electrotechnical Services**